

SVGW

Schweizerischer Verein
des Gas- und Wasserfaches
Grütlistrasse 44
CH- 8027 Zürich

Zertifizierungsstelle Wasser



Zertifikat Nr.: 0204-4489

Zertifikatsinhaber: Caleffi S.p.A., S.R. 229 n° 25, IT-28010 Fontaneto d'Agogna (NO)

Gestützt auf das Reglement ZW101 „Allgemeine Geschäftsbedingungen der SVGW Zertifizierungsstelle Wasser“ zertifiziert der SVGW die folgenden Serienprodukte:

Rubrik: Druckreduzierventile / Regelventile
Bezeichnung: Caleffi 535
Typen: 535040, 535042, 535050, 535052, 535060, 535070, 535080, 535090, 535140, 535150, 535160

DN: 15...50 PN: 16 tmax: 30 °C


Zertifizierungsgrundlage: SVGW ZW111 (01/19), EN 1567 (1999), ZW109/1 (01/22), EN13443-1 (2007)

Gültigkeit: 31.12.2027

Auflagen (A) / Bemerkungen (B):
Keine

Der Antragsteller ist berechtigt, die oben erwähnten Produkte als SVGW zertifiziert anzubieten und das obige SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Wasser).

Schweizerischer Verein des Gas- und Wasserfaches
Zertifizierungsstelle Wasser


Javier Fernandez
Leiter

Zürich, 16.01.2023

Seite 1 / 2

Rubrik: Druckreduzierventile / Regelventile

Bezeichnung: Caleffi 535

Typen	DN	PN	C°	Geräusch- gruppe	Verluste kWh/24 h / ErP Klasse	Inhalt	Index	Metrologie
535040	15	16	30	I	-	-	-	-
535042	15	16	30	I	-	-	-	-
535140	15	16	30	I	-	-	-	-
535050	20	16	30	II	-	-	-	-
535052	20	16	30	II	-	-	-	-
535150	20	16	30	I	-	-	-	-
535060	25	16	30	II	-	-	-	-
535160	25	16	30	I	-	-	-	-
535070	32	16	30	I	-	-	-	-
535080	40	16	30	-	-	-	-	-
535090	50	16	30	-	-	-	-	-

SGWA

Swiss Gas and Water
Industry Association
Grütlistrasse 44
CH- 8027 Zürich

Certification body water



Certificate No.: 0204-4489

Certificate holder: Caleffi S.p.A., S.R. 229 n° 25, IT-28010 Fontaneto d'Agogna (NO)

In accordance with our regulation ZW101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Pressure reduction valve

Denomination: Caleffi 535

Types: 535040, 535042, 535050, 535052, 535060, 535070, 535080, 535090, 535140, 535150, 535160

DN: 15...50 PN: 16 tmax: 30 °C

Certification Standard: SGWA ZW111 (01/19), EN 1567 (1999), ZW109/1 (01/22), EN13443-1 (2007)

Validity: 31.12.2027

Conditions (C) / Remarks (R):
None

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).

Swiss Gas and Water Industry Association
Certification body water

A blue ink signature of Javier Fernandez, consisting of a stylized 'J' followed by several vertical strokes and a horizontal line at the bottom.

Javier Fernandez
Head

Zurich, 16.01.2023

page 1 / 2

Rubric: Pressure reduction valve

Denomination: Caleffi 535

Types	DN	PN	C°	Acoustic group	Losses kWh/24 h / ErP Class	Content	Index	Metrology
535040	15	16	30	I	-	-	-	-
535042	15	16	30	I	-	-	-	-
535140	15	16	30	I	-	-	-	-
535050	20	16	30	II	-	-	-	-
535052	20	16	30	II	-	-	-	-
535150	20	16	30	I	-	-	-	-
535060	25	16	30	II	-	-	-	-
535160	25	16	30	I	-	-	-	-
535070	32	16	30	I	-	-	-	-
535080	40	16	30	-	-	-	-	-
535090	50	16	30	-	-	-	-	-